

number	305182/01	Replaces	-
Date of issue	15-02-2024	Issued first	15-02-2024
		Report number	P000320518

Declaration regarding the efficiency of a shower heat recovery unit

DECLARATION OF KIWA

This declaration is based on a single examination by Kiwa on a product supplied by

Zypho, SA

This declaration does not pass a judgment on other products supplied by the manufacturer. The products mentioned below were tested according the procedure according annex U of the NTA 8800:2023.


Zypho PiPe 55 DW

class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance (ΔP) (bar)
2	5.8	47	53.8	0.10
3	9.2	73	47.3	0.23
4, 5, 6	12.5	100	41.6	0.40

Zypho PiPe 60 DW

class	Flow (l/min)	Volume (l)	Efficiency (%)	Flow resistance (ΔP) (bar)
2	5.8	47	57.8	0.04
3	9.2	73	49.5	0.09
4, 5, 6	12.5	100	46.8	0.14

Allard Slomp
Product Manager



Kiwa Nederland B.V.

Zypho SA
Tower Plaza I,
Via Eng. Edgar Cardoso 23, 5º H
4400-676 Vila Nova de Gaia,
PORTUGAL
+351 210 991 351
b2b@zypho.pt
www.zypho.pt



Kiwa Nederland B.V.
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands
Tel. 088 998 33 55
info@kiwa.com
www.kiwaenergy.com

DECLARATION

